



नर्मदा विद्युत नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Jul-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jun-21	0:00:00	30-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 01.07.2021), 2 SSP-CHPH M/c are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	30-Jun-21	0:00:00	30-Jun-21	24:00:00	24:00:00	23.00	0.550	
3	30-Jun-21	0:00:00	30-Jun-21	0:00:00	0:00:00	0.00	0.000	
4	30-Jun-21	0:00:00	30-Jun-21	0:00:00	0:00:00	0.00	0.000	
5	30-Jun-21	0:00:00	30-Jun-21	24:00:00	24:00:00	25.00	0.574	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jun-21	0:00:00	30-Jun-21	24:00:00	24:00:00	152	3.570	Today (i.e. 01.07.2021), 2 SSP-RBPH M/cs are running at 10:00 hrs.
2	30-Jun-21	0:00:18:00	30-Jun-21	8:45:24:00	14:45:00	149	2.160	
3	30-Jun-21	0:00:00	30-Jun-21	24:00:00	24:00:00	149	3.508	
4	30-Jun-21	0:00:00	30-Jun-21	24:00:00	24:00:00	150	3.568	
5	30-Jun-21	19:00:00	30-Jun-21	24:00:00	5:00:00	145	0.724	
6	30-Jun-21	0:00:00	30-Jun-21	8:15:00	8:15:00	148	1.206	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.124	14.736	15.860
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	46.778	468.934	515.712
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	100:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	98:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	27:15:00	

SSP hydrological data : at 08:00 Hrs on 1-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 113.80 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13947 Cusec 34.12 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 36508 Cusec 89.32 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
9574	602

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
607	0	9641	8881	27627	234	31.00



जल संचयन - जल संरक्षण

Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil