



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Jul-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 03-Jul-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 04.07.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0.00	0.000	
3	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	3-Jul-21	11:00:00	3-Jul-21	24:00:00	13:00:00	23.00	0.289	
5	3-Jul-21	0:00:00	3-Jul-21	24:00:00	24:00:00	23.00	0.540	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 04.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	
3	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	
4	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	
5	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	
6	3-Jul-21	0:00:00	3-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.829	0.000	0.829
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	2.506	17.366	19.872
PREVIOUS DAY ACTUAL RUNNING HOURS	37:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Jul-21

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 113.22 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2779 Cusec 6.80 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7905 Cusec 19.34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6162	616

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	7550	7905	0	144	30.90



जल संपन्न - जल संरक्षक

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.6: 21:30 Hrs on 03.07.2021 to 06:05 Hrs on 04.07.2021.

Unit No.4: 22:30 Hrs on 03.07.2021 to 06:00 Hrs on 04.07.2021.

*Rajesh Sharma*  
Executive Engineer (EMC)  
NCA, INDORE  
4/07/21  
JE(EMC), NCA