



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jul-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Jul-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 11.07.2021), 1 SSP-CHPH M/c is running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0.00	0.000	
3	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	10-Jul-21	0:00:00	10-Jul-21	24:00:00	24:00:00	22.00	0.539	
5	10-Jul-21	00:00 12:45	10-Jul-21	1:30 24:00	12:45:00	24.00	0.279	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 11.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	
3	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	
4	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	
5	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	
6	10-Jul-21	0:00:00	10-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.818	0.000	0.818
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	8.430	17.366	25.796
PREVIOUS DAY ACTUAL RUNNING HOURS	36:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	33:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data - at 08:00 Hrs on 11-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 113.61 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13163 Cusec 32.20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7748 Cusec 18.96 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7515	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	7584	7748	0	145	20.50



जल संचयन - जल संरक्षण

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.
2. SCO Mode Detail:-
Nil.

Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

(Handwritten Signature)
J.E. (EMC)
EMC, NCA
11/07/2021