



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Jul-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 17-Jul-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 18.07.2021), 2 SSP-CHPH M/c are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0.00	0.000	
3	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	17-Jul-21	0:00:00	17-Jul-21	24:00:00	24:00:00	24.00	0.558	
5	17-Jul-21	0:00 19:00	17-Jul-21	9:00 24:00	14:00:00	23.00	0.316	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 18.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	
3	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	
4	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	
5	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	
6	17-Jul-21	0:00:00	17-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.874	0.000	0.874
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	14.581	17.366	31.947
PREVIOUS DAY ACTUAL RUNNING HOURS	38:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.86 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30419 Cusec 74.42 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6916 Cusec 16.92 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7264	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	7210	6916	0	151	20.50



*Archita Karanga*  
J. E. (Electrical)  
EMC, NCA

*P. Joshi*

Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, & Raj-1 lines are in service.

2. SCO Mode Detail:-

Nil