



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Jul-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-Jul-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 23.07.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	22-Jul-21	14:00:00	22-Jul-21	24:00:00	10:00:00	25.00	0.243 ✓	
3	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	22-Jul-21	0:00:00	22-Jul-21	10:00:00	10:00:00	25.00	0.244 ✓	
5	22-Jul-21	0:00:00	22-Jul-21	24:00:00	24:00:00	26.00	0.590 ✓	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 23.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	
3	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	
4	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	
5	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	
6	22-Jul-21	0:00:00	22-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.077	0.000	1.077
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.977	17.366	37.343
PREVIOUS DAY ACTUAL RUNNING HOURS	44:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.17 Mtrs.,
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9417 Cusec 23.04 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8156 Cusec 19.95 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
9032	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	9497	8156	0	154	20.50



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.6: 04:10 Hrs on 23.07.2021 to 06:15 Hrs on 23.07.2021.

Unit No.1: 04:35 Hrs on 23.07.2021 to 06:20 Hrs on 23.07.2021.