



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Jul-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 23-Jul-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 24.07.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	23-Jul-21	0:00:00	23-Jul-21	24:00:00	24:00:00	24.00	0.570	
3	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	23-Jul-21	12:00:00	23-Jul-21	20:30:00	8:30:00	26.00	0.208	
5	23-Jul-21	0:00:00	23-Jul-21	24:00:00	24:00:00	26.00	0.582	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 24.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	
3	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	
4	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	
5	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	
6	23-Jul-21	0:00:00	23-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.360	0.000	1.360
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	21.337	17.366	38.703
PREVIOUS DAY ACTUAL RUNNING HOURS	56:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.11 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24.Hrs). 6919 Cusec 16.93 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10268 Cusec 25.12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9497	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
613	0	9521	10268	0	154	20.50

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.6: 03:15 Hrs on 24.07.2021 to 06:10 Hrs on 24.07.2021.



*for* Archita Kawango  
J.E. (Elect.)  
24.7.21  
Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE