



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Jul-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 24-Jul-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 25.07.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	24-Jul-21	0:00:00	24-Jul-21	24:00:00	24:00:00	24.00	0.567	
3	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0.00	0.000	
5	24-Jul-21	0:00:00	24-Jul-21	24:00:00	24:00:00	24.00	0.564	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 25.07.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	
3	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	
4	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	
5	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	
6	24-Jul-21	0:00:00	24-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.131	0.000	1.131
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	22.468	17.366	39.834
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Jul-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.36 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 23653 Cusec 57.87 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8904 Cusec 21.78 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9521	613

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	9625	8904	0	154	20.50



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.5: 01:05 Hrs on 25.07.2021 to 06:50 Hrs on 25.07.2021.

Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Accepted  
J.E. (EMC)  
EMC, NCA  
25/07/2021