



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Aug-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 31-Jul-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 01.08.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	31-Jul-21	0:00:00	31-Jul-21	24:00:00	24:00:00	25.00	0.603	
3	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0.00	0.000	
4	31-Jul-21	10:00:00	31-Jul-21	24:00:00	14:00:00	26.00	0.358	
5	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	Today (i.e. 01.08.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	
3	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	
4	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	
5	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	
6	31-Jul-21	0:00:00	31-Jul-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.961	0.000	0.961
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	28.479	17.366	45.845
PREVIOUS DAY ACTUAL RUNNING HOURS	38:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	30:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Aug-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.42 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2888 Cusec 7.07 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7999 Cusec 19.57 MCM

GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6529	680

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
635	0	7212	7999	0	162	20.50



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 13:20 Hrs on 31.07.2021 to 06:40 Hrs on 01.08.2021.

Unit No.3: 13:30 Hrs on 31.07.2021 to 06:45 Hrs on 01.08.2021.

Unit No.5: 02:20 Hrs on 01.08.2021 to 6:50 Hrs on 01.08.2021.

Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

*Handwritten signature and date:*  
J. E. (E&M)  
EMC, N.C.A.  
01/08/2021