



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Aug-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 18-Aug-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Aug-21	18:52:00	18-Aug-21	24:00:00	5:08:00	25.00	0.129	Today (i.e. 19.08.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	18-Aug-21	0:00:00	18-Aug-21	24:00:00	24:00:00	25.00	0.588	
3	18-Aug-21	1:00:00	18-Aug-21	24:00:00	23:00:00	26.00	0.583	
4	18-Aug-21	0:00 11:45	18-Aug-21	6:00 18:58	13:13:00	26.00	0.332	
5	18-Aug-21	0:00:00	18-Aug-21	15:30:00	15:30:00	26.00	0.373	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	Today (i.e. 19.08.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	
3	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	
4	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	
5	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	
6	18-Aug-21	0:00:00	18-Aug-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.005	0.000	2.005
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	29.442	0.000	29.442
PREVIOUS DAY ACTUAL RUNNING HOURS	80:51:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Aug-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19530 Cusec 47.78 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14153 Cusec 34.63 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15488	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	15689	14153	0	123	20.50



जल वनस्पति जल संयंत्र

Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 4:15 Hrs on 19.08.2021 to 06:20 Hrs on 19.08.2021.