



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Aug-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 22-Aug-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Aug-21	0:00:00	22-Aug-21	24:00:00	24:00:00	26.00	0.591	Today (i.e. 23.08.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	22-Aug-21	0:00:00	22-Aug-21	24:00:00	24:00:00	25.00	0.593	
3	22-Aug-21	0:00:00	22-Aug-21	24:00:00	24:00:00	26.00	0.611	
4	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0.00	0.000	
5	22-Aug-21	4:00 17:00	22-Aug-21	10:00 21:00	10:00:00	26.00	0.240	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	Today (i.e. 23.08.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	
3	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	
4	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	
5	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	
6	22-Aug-21	0:00:00	22-Aug-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.035 ✓	0.000 ✓	2.035 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	37.409	0.000	37.409
PREVIOUS DAY ACTUAL RUNNING HOURS	82:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Aug-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.82 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 21298 Cusec 52.11 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14753 Cusec 36.09 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
15577	621 ✓

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	15690 ✓	14753 ✓	0	123	20.50 ✓



*Rajesh Sharma*  
23/8/21  
Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 00:50 Hrs on 23.08.2021 to 06:15 Hrs on 23.08.2021. ✓

Unit No.3: 12:55 Hrs on 22.08.2021 to 06:20 Hrs on 23.08.2021. ✓

Unit No.6: 12:45 Hrs on 22.08.2021 to 06:30 Hrs on 23.08.2021. ✓

Unit No.5: 00:40 Hrs on 23.08.2021 to 06:25 Hrs on 23.08.2021. ✓