



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Aug-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Aug-21

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 31-Aug-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUcs	REMARKS
1	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 31.08.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	30-Aug-21	0:00:00	30-Aug-21	24:00:00	24:00:00	26.00	0.613 ✓	
3	30-Aug-21	0:00:00	30-Aug-21	24:00:00	24:00:00	26.00	0.603 ✓	
4	30-Aug-21	0:00:00	30-Aug-21	24:00:00	24:00:00	26.00	0.608 ✓	
5	30-Aug-21	9:00:00	30-Aug-21	12:30:00	3:30:00	26.00	0.088	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUcs	REMARKS
1	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	Today (i.e. 31.08.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	
3	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	
4	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	
5	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	
6	30-Aug-21	0:00:00	30-Aug-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUcs)	1.912 ✓	0.000 ✓	1.912
CUMMULATIVE GROSS GEN. FOR MONTH (MUcs)	52.742	7.374	60.116
PREVIOUS DAY ACTUAL RUNNING HOURS	75:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Aug-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.38 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18155 Cusec 44.42 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13943 Cusec 34.11 MCM ✓
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14909	616

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	14935	13943	0	125	30.00



Rajesh Sharma
31/8/21.
Rajesh Sharma
Executive Engineer (EMC)
NCA, Indore

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.6: 20:10 Hrs on 30.08.2021 to 07:05 Hrs on 31.08.2021.

Unit No.3: 20:20 Hrs on 30.08.2021 to 07:10 Hrs on 31.08.202.