



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 02.09.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	1-Sep-21	0:00:00	1-Sep-21	24:00:00	24:00:00 ✓	27.00	0.632 ✓	
3	1-Sep-21	0:00:00	1-Sep-21	24:00:00	24:00:00 ✓	27.00	0.633 ✓	
4	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 02.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	
3	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	
4	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	
5	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	
6	1-Sep-21	0:00:00	1-Sep-21	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		1.265	0.000	1.265 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		1.265	0.000	1.265 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS		48:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.81 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19139 Cusec ✓ 46.82 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9012 Cusec ✓ 22.05 MCM ✓
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
11654	623

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
624	0	9017	9012	0	202	30.00



Rajesh Sharma
29/9/21
Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service. ✓

2. SCO Mode Detail:-

Nil