



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Sep-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 03-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Sep-21	19:00:00	3-Sep-21	24:00:00	5:00:00	28.00	0.138	Today (i.e. 04.09.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	3-Sep-21	0:00:00	3-Sep-21	9:00:00	9:00:00	27.00	0.240	
3	3-Sep-21	0:00:00	3-Sep-21	24:00:00	24:00:00	27.00	0.634	
4	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 04.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	
3	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	
4	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	
5	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	
6	3-Sep-21	0:00:00	3-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.012	0.000	1.012
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	3.549	0.000	3.549
PREVIOUS DAY ACTUAL RUNNING HOURS	38:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 26621 Cusec 65.13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5983 Cusec 14.64 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7008	629

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	5552	5983	0	205	30.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.3: 21:10 Hrs on 03.09.2021 to 06:05 Hrs on 04.09.2021.

Unit No.4: 21:40 Hrs on 03.09.2021 to 06:10 Hrs on 04.09.2021.

Unit No.6: 21:20 Hrs on 03.09.2021 to 06:15 Hrs on 04.09.2021.

Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

*Tausif Ah*  
*JE(EMC) 4/9/21*