



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Sep-21	0:00:00	4-Sep-21	1:00:00	1:00:00	28.00	0.028	Today (i.e. 05.09.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	4-Sep-21	0:00:00	4-Sep-21	18:00:00	18:00:00	28.00	0.490	
4	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 05.09.2021), 0 SSP-RBPB M/c is running at 10:00 hrs.
2	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	
3	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	
4	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	
5	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	
6	4-Sep-21	0:00:00	4-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.518	0.000	0.518
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	4.067	0.000	4.067
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	18:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.49 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14163 Cusec 34.65 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2281 Cusec 5.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5551	622

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
623	0	3237	2281	0	207	30.00



Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

J.E. (Elect)
EMC, N.C.D.
05/09/2021