



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Sep-21	0:00 17:30	6-Sep-21	9:00 24:00	15:30:00	28.00	0.421	Today (i.e. 07.09.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 07.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	
3	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	
4	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	
5	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	
6	6-Sep-21	0:00:00	6-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.421	0.000	0.421
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.972	0.000	4.972
PREVIOUS DAY ACTUAL RUNNING HOURS	15:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10181 Cusec 24.91 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2967 Cusec 7.26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3270	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
631	0	3202	2967	0	208	30.00



Rajesh Sharma
7/9/21
Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. 400kV SSP-Asoj is out at 9:55hrs.

3. SCO Mode Detail:-

Nil