



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Sep-21	0:00 17:30	7-Sep-21	12:30 24:00	19:00:00	29.00	0.527	Today (i.e. 08.09.2021), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 08.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	
3	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	
4	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	
5	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	
6	7-Sep-21	0:00:00	7-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.527	0.000	0.527
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	5.499	0.000	5.499
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 118.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 46323 Cusec 113.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2326 Cusec 5.69 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3202	631

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	2990	2326	0	212	30.00



Rajesh Sharma
Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE
9/9/21.

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 2:50 Hrs on 08.09.2021 to 06:20 Hrs on 08.09.2021.

Unit No.2: 3:20 Hrs on 08.09.2021 to 06:25 Hrs on 08.09.2021