



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Sep-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 08-Sep-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	8-Sep-21	0:00:00	8-Sep-21	0:42:00	0:42:00	0.00	0.020	Today (i.e. 09.09.2021), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	8-Sep-21	1:00 17:30	8-Sep-21	9:00 24:00	14:30:00	28.00	0.395	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 09.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	
3	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	
4	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	
5	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	
6	8-Sep-21	0:00:00	8-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.415	0.000	0.415
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	5.914	0.000	5.914
PREVIOUS DAY ACTUAL RUNNING HOURS	15:12:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 37494 Cusec 91.73 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2833 Cusec 6.93 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2990	619

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	2785	2833	0	216	30.00



*Rajesh Sharma*  
9/9/21  
Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.4: 00:35 Hrs on 09.09.2021 to 06:30 Hrs on 09.09.2021.

Unit No.2: 00:40 Hrs on 09.09.2021 to 06:35 Hrs on 09.09.2021