



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 13.09.2021), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	12-Sep-21	14:00:00	12-Sep-21	24:00:00	10:00:00	31.00	0.298	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 13.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	
3	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	
4	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	
5	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	
6	12-Sep-21	0:00:00	12-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.298	0.000	0.298
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	7.260	0.000	7.260
PREVIOUS DAY ACTUAL RUNNING HOURS	10:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.22 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20694 Cusec 50.63 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 1841 Cusec 4.50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1737	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
612	0	1788	1841	0	227	30.00



Rajesh Sharma

Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 15:25 Hrs on 12.09.2021 to 06:35 Hrs on 13.09.2021.

Unit No.3: 15:40 Hrs on 12.09.2021 to 06:40 Hrs on 13.09.2021.