



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Sep-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 13-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 14.09.2021), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	13-Sep-21	14:30:00	13-Sep-21	22:15:00	7:45:00	34.00	0.258	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 14.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	
3	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	
4	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	
5	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	
6	13-Sep-21	0:00:00	13-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUS)	0.258	0.000	0.258
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	7.518	0.000	7.518
PREVIOUS DAY ACTUAL RUNNING HOURS	7:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18839 Cusec 46.09 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 1579 Cusec 3.86 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1787	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
314	0	1794	1579	0	229	30.00



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 22:15 Hrs on 13.09.2021 to 06:20 Hrs on 14.09.2021.

Unit No.6: 22:20 Hrs on 13.09.2021 to 06:20 Hrs on 14.09.2021.