



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Sep-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 17-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 18.09.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	17-Sep-21	8:00:00	17-Sep-21	20:30:00	12:30:00	35.00	0.419	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 18.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	
3	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	
4	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	
5	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	
6	17-Sep-21	0:00:00	17-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.419	0.000	0.419
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	9.049	0.000	9.049
PREVIOUS DAY ACTUAL RUNNING HOURS	12:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	15:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20464 Cusec 50.07 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2454 Cusec 6.00 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2206	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	2154	2454	0	239	30.00



Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.3: 01:40 Hrs on 18.09.2021 to 06:30 Hrs on 18.09.2021.

Unit No.6: 01:45Hrs on 18.09.2021 to 06:35 Hrs on 18.09.2021.

*Signature*  
J.E. (Elect)  
EMC, NCA  
18/09/21