



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Sep-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 18-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 19.09.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	18-Sep-21	9:00:00	18-Sep-21	22:00:00	13:00:00	36.00	0.449	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 19.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	
3	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	
4	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	
5	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	
6	18-Sep-21	0:00:00	18-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.449	0.000	0.449
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	9.498	0.000	9.498
PREVIOUS DAY ACTUAL RUNNING HOURS	13:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	15:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.53 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20620 Cusec 50.45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2606 Cusec 6.38 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2154	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
642	0	2182	2606	0	242	30.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.3: 02:05 Hrs on 19.09.2021 to 07:35 Hrs on 19.09.2021.

Unit No.6: 02:15 Hrs on 19.09.2021 to 07:40 Hrs on 19.09.2021.

*Tausif A*  
*7/9/2021*  
*JEC(EMC)*