



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Sep-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 24-Sep-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 25.09.2021), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0.00	0.000	
3	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0.00	0.000	
4	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0.00	0.000	
5	24-Sep-21	11:00:00	24-Sep-21	19:15:00	8:15:00	36.00	0.299	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	Today (i.e. 25.09.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	
3	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	
4	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	
5	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	
6	24-Sep-21	0:00:00	24-Sep-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.299	0.000	0.299
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	11.794	0.000	11.794
PREVIOUS DAY ACTUAL RUNNING HOURS	8:15:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs . on 25-Sep-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 22617 Cusec 55.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 1620 Cusec 3.96 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1956	333

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	1951	1620	0	264	30.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 22:00 Hrs on 24.09.2021 to 06:05 Hrs on 25.09.2021.

Unit No.6: 22:10 Hrs on 24.09.2021 to 06:10 Hrs on 25.09.2021.