



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Oct-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Oct-21	10:15:00	1-Oct-21	18:00:00	7:45:00	45.00	0.321	Today (i.e. 02.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	1-Oct-21	8:00:00	1-Oct-21	11:15:00	3:15:00	44.00	0.123	
4	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0.00	0.000	
5	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 02.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	
3	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	
4	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	
5	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	
6	1-Oct-21	0:00:00	1-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUS)	0.444	0.000	0.444
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.444	0.000	0.444
PREVIOUS DAY ACTUAL RUNNING HOURS	11:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.14 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 55870 Cusec 136.69 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2924 Cusec 7.15 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4547	614

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	2571	2924	0	453	30.00



Archita Kanungo
(Rajesh Sharma)
Executive Engineer (EMC)
EMC, NCA.

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil