



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Oct-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 02-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	2-Oct-21	4:00:00	2-Oct-21	16:00:00	12:00:00	48.00	0.560	Today (i.e. 03.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0.00	0.000	
4	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0.00	0.000	
5	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 03.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	
3	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	
4	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	
5	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	
6	2-Oct-21	0:00:00	2-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.560	0.000	0.560
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	1.004	0.000	1.004
PREVIOUS DAY ACTUAL RUNNING HOURS	12:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	20:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 55593 Cusec 136.01 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2636 Cusec 6.45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2571	619

· AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	2503	2636	0	464	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

(Handwritten Signature)
J. E. (EMC)
EMC, NCA
03/10/21