



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Oct-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Oct-21	15:00:00	15-Oct-21	24:00:00	9:00:00	50.00	0.444	Today (i.e. 16.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0.00	0.000	
4	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0.00	0.000	
5	15-Oct-21	0:00:00	15-Oct-21	8:30:00	8:30:00	49.00	0.415	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 16.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	
3	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	
4	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	
5	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	
6	15-Oct-21	0:00:00	15-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.859	0.000	0.859
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.833	0.000	9.833
PREVIOUS DAY ACTUAL RUNNING HOURS	17:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	23:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.64 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6147 Cusec 15.04 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2806 Cusec 6.87 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2843	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	2837	2806	0	530	30.00



for Sharma
16/10/21
Raj. EMC, Indore

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.3: 03:35 Hrs on 16.10.2021 to 06:55 Hrs on 16.10.2021.

Unit No.4: 03:10 Hrs on 16.10.2021 to 07:00 Hrs on 16.10.2021.