



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-Oct-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 16-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	16-Oct-21	0:00:00	16-Oct-21	2:30:00	2:30:00	50.00	0.123	Today (i.e. 17.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0.00	0.000	
4	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0.00	0.000	
5	16-Oct-21	7:00:00	16-Oct-21	20:30:00	13:30:00	50.00	0.668	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 17.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	
3	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	
4	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	
5	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	
6	16-Oct-21	0:00:00	16-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.791	0.000	0.791
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.624	0.000	10.624
PREVIOUS DAY ACTUAL RUNNING HOURS	16:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	20:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 17-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5968 Cusec 14.60 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3563 Cusec 8.72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2837	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	2825	3563	0	530	30.00



for Sharma
17/10/21
→ EEM/CA

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-