



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Oct-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 17-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Oct-21	4:00:00	17-Oct-21	20:00:00	20:00:00	50.00	0.964	Today (i.e. 18.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0.00	0.000	
4	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0.00	0.000	
5	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 18.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	
3	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	
4	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	
5	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	
6	17-Oct-21	0:00:00	17-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	0.964	0.000	0.964
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.588	0.000	11.588
PREVIOUS DAY ACTUAL RUNNING HOURS	20:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9277 Cusec 22.70 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4997 Cusec 12.23 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
3589	617

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	3797	4997	0	531	30.00



for *sharma*  
18/10/21

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 00:35 Hrs on 18.10.2021 to 06:25Hrs on 18.10..2021.

Unit No.6: 00:50 Hrs on 18.10.2021 to 06:30Hrs on 18.10.2021.