



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Oct-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 20-Oct-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 21.10.2021), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0.00	0.000	
3	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0.00	0.000	
4	20-Oct-21	14:00:00	20-Oct-21	24:00:00	10:00:00	50.00	0.504	
5	20-Oct-21	0:00:00	20-Oct-21	19:00:00	19:00:00	50.00	0.943	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	Today (i.e. 21.10.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	
3	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	
4	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	
5	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	
6	20-Oct-21	0:00:00	20-Oct-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.447	0.000	1.447
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.021	0.000	15.021
PREVIOUS DAY ACTUAL RUNNING HOURS	29:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	37:45:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 21-Oct-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8720 Cusec 21.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6311 Cusec 15.44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4356	617

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	5862.00	6311	0	534	30.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil