



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Nov-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 02-Nov-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 03.11.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-Nov-21	0:00:00	2-Nov-21	24:00:00	24:00:00	50.00	1.200	
3	2-Nov-21	16:45:00	2-Nov-21	24:00:00	7:15:00	50.00	0.358	
4	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0.00	0.000	
5	2-Nov-21	0:00:00	2-Nov-21	16:50:00	16:50:00	50.00	0.831	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	Today (i.e. 03.11.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	
3	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	
4	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	
5	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	
6	2-Nov-21	0:00:00	2-Nov-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.389	0.000	2.389
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	4.774	0.000	4.774
PREVIOUS DAY ACTUAL RUNNING HOURS	48:05:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Nov-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.08 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7996 Cusec 19.56 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10347 Cusec 25.31 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
10381	619

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	10657.00	10347	0	461	27.00



*(Signature)*  
3/11/21

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.6: 20:30 Hrs on 2.11.2021 to 06:30 Hrs on 3.11.2021.

Unit No.4: 20:25 Hrs on 2.11.2021 to 06:35 Hrs on 3.11.2021.