



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Nov-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Nov-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Nov-21	18:00:00	6-Nov-21	24:00:00	6:00:00	50.00	0.298	Today (i.e. 07.11.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	6-Nov-21	0:00:00	6-Nov-21	24:00:00	24:00:00	51.00	1.208	
3	6-Nov-21	0:00:00	6-Nov-21	24:00:00	24:00:00	51.00	1.201	
4	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0.00	0.000	
5	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	Today (i.e. 07.11.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	
3	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	
4	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	
5	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	
6	6-Nov-21	0:00:00	6-Nov-21	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.707	0.000	2.707
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		15.224	0.000	15.224
PREVIOUS DAY ACTUAL RUNNING HOURS		54:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Nov-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.82 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5637 Cusec 13.79 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11741 Cusec 28.73 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11954	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	11945.00	11741	0	457	27.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 13:55 Hrs on 06.11.2021 to 05:45 Hrs on 07.11.2021.

Unit No.4: 14:05 Hrs on 06.11.2021 to 05:55 Hrs on 07.11.2021.

Unit No.6: 20:00 Hrs on 06.11.2021 to 06:00 Hrs on 07.11.2021.

Unit No.3: 20:10 Hrs on 06.11.2021 to 05:50 Hrs on 07.11.2021.

Tausif Akh
07/11/2021
JE(EMC)