



सर्दार सरोवर प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Nov-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Nov-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Nov-21	1:00 15:00	15-Nov-21	7:15 23:00	14:15:00	51.00	0.709	Today (i.e. 16.11.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	15-Nov-21	0:00:00	15-Nov-21	24:00:00	24:00:00	51.00	1.204	
3	15-Nov-21	0:00:00	15-Nov-21	24:00:00	24:00:00	50.00	1.196	
4	15-Nov-21	0:00:00	15-Nov-21	19:00:00	19:00:00	50.00	0.946	
5	15-Nov-21	18:50:00	15-Nov-21	24:00:00	5:10:00	51.00	0.252	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	Today (i.e. 16.11.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	
3	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	
4	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	
5	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	
6	15-Nov-21	0:00:00	15-Nov-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.307	0.000	4.307
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	47.548	0.000	47.548
PREVIOUS DAY ACTUAL RUNNING HOURS	86:25:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Nov-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10971 Cusec 26.84 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18019 Cusec 44.08 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17728	614

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
613	0	18716	18019	0	450	27.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

16/11/21

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah: CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Made Detail:-

Unit No.2: 20:25 Hrs on 15.11.2021 to 06:10 Hrs on 16.11.2021.

Unit No.5: 20:35 Hrs on 15.11.2021 to 06:15 Hrs on 16.11.2021.