



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Nov-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 19-Nov-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Nov-21	0:00:00	19-Nov-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 20.11.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	19-Nov-21	0:00:00	19-Nov-21	24:00:00	24:00:00	51.00	1.201	
3	19-Nov-21	0:00:00	19-Nov-21	24:00:00	24:00:00	50.00	1.193	
4	19-Nov-21	0:00:00	19-Nov-21	0:00:00	0:00:00	0.00	0.000	
5	19-Nov-21	0:00:00 11:45:00	19-Nov-21	5:00:00 19:30:00	12:45:00	50.00	0.621	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Nov-21	17:15:00	19-Nov-21	23:30:00	6:15:00	204	1.262	Today (i.e. 20.11.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	19-Nov-21	0:00:00	19-Nov-21	0:15:00	0:15:00	196	0.050	
3	19-Nov-21	17:30:00	19-Nov-21	23:45:00	6:15:00	204	1.264	
4	19-Nov-21	0:00:00	19-Nov-21	0:30:00	0:30:00	196	0.098	
5	19-Nov-21	0:00:00	19-Nov-21	0:00:00	0:00:00	0	0.000	
6	19-Nov-21	0:00:00 17:45	19-Nov-21	0:45 24:00	7:00:00	204	1.422	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.015	4.096	7.111
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	64.006	8.566	72.572
PREVIOUS DAY ACTUAL RUNNING HOURS	60:45:00	20:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	20:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	20:15:00	

SSP hydrological data : at 08:00 Hrs on 20-Nov-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 130.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14960 Cusec 36.60 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19201 Cusec 46.98 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17426	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	12303	12314	6887	446	27.00



for Archita Kavunge
S.E. (Elect.)
20.11.21
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 20:25 Hrs on 19.11.2021 to 05:55 Hrs on 20.11.2021.

Unit No.5: 20:30 Hrs on 19.11.2021 to 06:00 Hrs on 20.11.2021.