



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Nov-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 27-Nov-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Nov-21	00:00 19:00	27-Nov-21	9:40 24:00	14:40:00	50.00	0.723	Today (i.e. 28.11.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Nov-21	0:00:00	27-Nov-21	24:00:00	24:00:00	51.00	1.200	
3	27-Nov-21	0:00:00	27-Nov-21	24:00:00	24:00:00	51.00	1.208	
4	27-Nov-21	9:40:00	27-Nov-21	24:00:00	14:20:00	51.00	0.669	
5	27-Nov-21	0:00:00	27-Nov-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Nov-21	16:30:00	27-Nov-21	19:45:00	3:15:00	203	0.658	Today (i.e. 28.11.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	27-Nov-21	6:00 16:45	27-Nov-21	8:45 20:00	6:00:00	202	1.208	
3	27-Nov-21	6:15 17:00	27-Nov-21	12:00 20:15	9:00:00	202	1.794	
4	27-Nov-21	0:00:00	27-Nov-21	0:00:00	0:00:00	0	0.000	
5	27-Nov-21	0:00:00	27-Nov-21	0:00:00	0:00:00	0	0.000	
6	27-Nov-21	17:15:00	27-Nov-21	20:30:00	3:15:00	202	0.652	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.800	4.312	8.112
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	91.867	41.926	133.793
PREVIOUS DAY ACTUAL RUNNING HOURS	77:00:00	21:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	20:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	20:30:00	

SSP hydrological data : at 08:00 Hrs on 28-Nov-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 129.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9664 Cusec 23.64 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24232 Cusec 59.29 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17835	614

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	17437	17257	6975	431	27.50



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 5: 03:05hrs on 28.11.2021 to 05:10 hrs on 28.11.2021.

Unit No. 4: 03:15 hrs on 28.11.2021 to 05:15 hrs on 28.11.2021.

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

28/11/21
J.E. (E&M)
EMC, NCA