



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Dec-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 06-Dec-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Dec-21	0:00:00	6-Dec-21	24:00:00	24:00:00	50.00	1.186	Today (i.e. 07.12.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	6-Dec-21	0:00:00	6-Dec-21	24:00:00	24:00:00	50.00	1.195	
3	6-Dec-21	0:00:00	6-Dec-21	24:00:00	24:00:00	51.00	1.196	
4	6-Dec-21	0:00:00	6-Dec-21	0:00:00	0:00:00	0.00	0.000	
5	6-Dec-21	10:00:00	6-Dec-21	18:00:00	8:00:00	50.00	0.390	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Dec-21	0:00:00	6-Dec-21	0:00:00	0:00:00	0	0.000	Today (i.e. 07.12.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	6-Dec-21	0:00:00	6-Dec-21	0:00:00	0:00:00	0	0.000	
3	6-Dec-21	0:00:00	6-Dec-21	0:00:00	0:00:00	0	0.000	
4	6-Dec-21	0:00:00	6-Dec-21	0:00:00	0:00:00	0	0.000	
5	6-Dec-21	6:15:00	6-Dec-21	9:15:00	3:00:00	197	0.602	
6	6-Dec-21	12:15:00	6-Dec-21	19:00:00	6:45:00	201	1.346	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.967	1.948	5.915
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	20.163	15.190	35.353
PREVIOUS DAY ACTUAL RUNNING HOURS	80:00:00	9:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	9:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	9:45:00	

SSP hydrological data : at 08:00 Hrs on 7-Dec-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.59 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14030 Cusec 34.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21166 Cusec 51.78 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18090	631

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	19512	18135	3031	362	28.00



*(Signature)*  
7/12/21

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.5: 21:35 Hrs on 06.12.2021 to 5:55 Hrs on 07.12.2021.

Unit No.6: 21:40 Hrs on 06.12.2021 to 6:00 Hrs on 07.12.2021.