



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Dec-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Dec-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Dec-21	0:00:00	10-Dec-21	24:00:00	24:00:00	48.00	1.169	Today (i.e. 11.12.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-Dec-21	0:00:00	10-Dec-21	24:00:00	24:00:00	50.00	1.196	
3	10-Dec-21	0:00:00	10-Dec-21	0:00:00	0:00:00	0.00	0.000	
4	10-Dec-21	0:00:00	10-Dec-21	24:00:00	24:00:00	50.00	1.194	
5	10-Dec-21	15:00:00	10-Dec-21	18:30:00	3:30:00	51.00	0.178	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Dec-21	0:00:00	10-Dec-21	0:00:00	0:00:00	0	0.000	Today (i.e. 11.12.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	10-Dec-21	0:00:00	10-Dec-21	0:00:00	0:00:00	0	0.000	
3	10-Dec-21	0:00:00	10-Dec-21	0:00:00	0:00:00	0	0.000	
4	10-Dec-21	0:00:00	10-Dec-21	0:00:00	0:00:00	0	0.000	
5	10-Dec-21	12:15:00	10-Dec-21	19:00:00	6:45:00	196	1.332	
6	10-Dec-21	5:45:00	10-Dec-21	8:30:00	2:45:00	201	0.552	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.737	1.884	5.621
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	35.646	22.934	58.580
PREVIOUS DAY ACTUAL RUNNING HOURS	75:30:00	9:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Dec-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.23 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13236 Cusec 32.38 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19441 Cusec 47.56 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17983	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	17618	17149	2292	357	28.00



for Sharma
11/12/21
NCA

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.3: 20:25 Hrs on 10.12.2021 to 5:40 Hrs on 11.12.2021.

Unit No.6: 20:55 Hrs on 10.12.2021 to 5:45 Hrs on 11.12.2021.