



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Dec-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 18-Dec-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Dec-21	0:00:00	18-Dec-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 19.12.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	18-Dec-21	0:00:00	18-Dec-21	24:00:00	24:00:00	51.00	1.209	
3	18-Dec-21	0:00:00	18-Dec-21	24:00:00	24:00:00	50.00	1.200	
4	18-Dec-21	0:00:00	18-Dec-21	24:00:00	24:00:00	51.00	1.205	
5	18-Dec-21	7:00:00	18-Dec-21	12:00:00	5:00:00	48.00	0.234	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Dec-21	0:00:00	18-Dec-21	0:00:00	0:00:00	0	0.000	Today (i.e. 19.12.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	18-Dec-21	0:00:00	18-Dec-21	0:00:00	0:00:00	0	0.000	
3	18-Dec-21	16:30:00	18-Dec-21	19:15:00	2:45:00	197	0.542	
4	18-Dec-21	0:00:00	18-Dec-21	0:00:00	0:00:00	0	0.000	
5	18-Dec-21	16:45:00	18-Dec-21	19:30:00	2:45:00	190	0.526	
6	18-Dec-21	17:00:00	18-Dec-21	19:45:00	2:45:00	196	0.536	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.848	1.604	5.452
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	66.257	26.162	92.419
PREVIOUS DAY ACTUAL RUNNING HOURS	77:00:00	8:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	8:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Dec-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.01 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 300 Cusec 0.73 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20567 Cusec 50.32 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17016	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	17986	18010	2557	355	27.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.4: 20:00 Hrs on 18.12.2021 to 07:15 Hrs on 19.12.2021.

Unit No.5: 20:15 Hrs on 18.12.2021 to 07:20 Hrs on 19.12.2021.

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

19/12/21  
J. E. (E&M)  
EMC, NCA