



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Dec-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Dec-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-21	12:00:00	20-Dec-21	18:30:00	6:30:00	50.00	0.322	Today (i.e. 21.12.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	20-Dec-21	0:00:00	20-Dec-21	24:00:00	24:00:00	51.00	1.194	
3	20-Dec-21	0:00:00	20-Dec-21	24:00:00	24:00:00	50.00	1.198	
4	20-Dec-21	0:00:00	20-Dec-21	24:00:00	24:00:00	50.00	1.186	
5	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	Today (i.e. 21.12.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	
3	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	
4	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	
5	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	
6	20-Dec-21	0:00:00	20-Dec-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.900	0.000	3.900
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	74.008	27.774	101.782
PREVIOUS DAY ACTUAL RUNNING HOURS	78:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 21-Dec-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.56 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 160 Cusec 0.39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17997 Cusec 44.03 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
19027	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	19027	17997	0	348	27.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.5: 23:55 Hrs on 20.12.2021 to 5:40 Hrs on 21.12.2021.

Unit No.6: 23:45 Hrs on 20.12.2021 to 5:45 Hrs on 21.12.2021.