




NARMADA CONTROL AUTHORITY, REGIONAL OFFICE
HYDROLOGY DIRECTORATE, INDORE
Daily Status of Narmada River Basin at 08:00 hrs. on 03 August, 2021



S. No	Name of Station	FRL/Danger level	Water Level	Live Storage as on today	Inflow/ # Discharge	Average Outflows during last 24 hrs.					RAINFALL		Rainfall in other sites during the last 24 hours in mm	
		Meter	Metre	MCM	Cumec	Spillway	PH Rel.		HR Rel.	Total Rel.	24 Hrs	15 June		
						Cumec	RBPB	CHPH	Cumec	Cumec	mm	mm		
1	Bargi Reservoir	422.76	418.30	2016	1234	-	177.7	29.7	15.0	222.5	-	154.0	Pachmari	22.6
2	Burmanghat	322.00	310.08	-	371						0.8	449.4	Molgi	14.0
3	Tawa Reservoir	355.40	350.76	1155	610	-	-	-	0.4	0.4	-	537.0	Barna	10.5
4	Hoshangabad	293.83	286.30	-	1211						-	344.8		
5	ISP Reservoir	262.13	249.46	1780	1012	-	136.4	-	-	136.4	-	361.2		
6	OSP Reservoir	196.60	194.73	116	*	-	421.8	-	-	421.8	5.4	375.4		
7	Maheshwar Reservoir	162.76	146.30	-	-						7.0	208.6		
8	SSP Reservoir	138.68	116.38	701	217	-	0.0	213.8	252.3 [§]	213.8	2.8	174.2		

Power Generation from Sardar Sarovar Project **1.053 MU/s**

Average discharge measured at (i) Godbole Weir **616 (01.00hrs) Cusecs** Garudeshwar Weir **622 Cusecs** Ex-MP Releases **14897 Cusecs**
(ii) Gujarat-Rajasthan Border **180** **36.45 MCM**



Note: # - Water level, Discharge (at G&D site) & Live Storage are at 08:00 hrs on the day # - Inflow (into reservoir), Spillway, PH & HR releases are 24 hours average of preceding day.

§ - Water released through CHPH/IBPT is diverted to HR of NMC & Godbole gate for env. use.

* As the releases/outflows are not matching with that of change in storage, inflow is not reported.

Copy forwarded to

- NCA : Executive Member, Member(Civil/Power/E&R), Chief Engineer, Director (Civil), Director (IA&R), SE (EMC), NCA, Indore.
- GoMP : Vice Chairman, NVDA, Member (Engg), NVDA, Bhopal
- GoG : Director (Civil), SSNNL, Gandhi Nagar, Chief Engineer (D&V), SSNNL, Vadodara, SE (Design), SSNNL, Vadodara
- GoM : Chief Engineer, Tapi Irrigation Development Corporation Ltd Jalgaon.
- GoR : Chief Engineer, NMC, Sanchore

(R Parmar)
Assistant Director (HM)