



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Jan-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Jan-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	5-Jan-22	16:10:00	5-Jan-22	24:00:00	7:50:00	47.00	0.360	Today (i.e. 06.01.2022), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	5-Jan-22	0:00:00	5-Jan-22	24:00:00	24:00:00	48.00	1.122	
3	5-Jan-22	00:00 06:30 11:50	5-Jan-22	02:52 10:42 15:23	10:37:00	47.00	0.462	
4	5-Jan-22	3:35:00	5-Jan-22	24:00:00	20:25:00	47.00	0.918	
5	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	Today (i.e. 06.01.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. SSP RBPH Unit No. 2 is under AOH from 24.12.2021.
2	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	
3	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	
4	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	
5	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	
6	5-Jan-22	0:00:00	5-Jan-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.862	0.000	2.862
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	17.649	0.000	17.649
PREVIOUS DAY ACTUAL RUNNING HOURS	62:52:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Jan-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 126.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13199 Cusec 32.29 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15670 Cusec 38.34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14307	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
641	0	15015	15670	0	341	27.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:- Nil