



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Jan-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 07-Jan-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jan-22	0:00:00	7-Jan-22	11:00:00	11:00:00	47.00	0.510	Today (i.e. 08.01.2022), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	7-Jan-22	0:00:00	7-Jan-22	24:00:00	24:00:00	48.00	1.130	
3	7-Jan-22	0:00:00	7-Jan-22	24:00:00	24:00:00	49.00	1.125	
4	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0.00	0.000	
5	7-Jan-22	18:00:00	7-Jan-22	24:00:00	6:00:00	49.00	0.283	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	Today (i.e. 08.01.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. SSP RBPH Unit No. 2 is under AOH from 24.12.2021.
2	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	
3	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	
4	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	
5	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	
6	7-Jan-22	0:00:00	7-Jan-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.048	0.000	3.048
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	24.207	0.000	24.207
PREVIOUS DAY ACTUAL RUNNING HOURS	65:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Jan-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 126.24 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6688 Cusec 16.36 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14786 Cusec 36.18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16420	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	15117	14786	0	339	27.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 21:25 hrs on 07.01.2022 to 06:45 hrs on 08.01.2022.

Unit No. 4: 21:40 hrs on 07.01.2022 to 06:50 hrs on 08.01.2022.

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

*Handwritten signature and date:*  
08/01/22  
T.E. (Elect)  
EMC, N.C.A.