



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Jan-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 08-Jan-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 09.01.2022), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	8-Jan-22	0:00:00	8-Jan-22	24:00:00	24:00:00	47.00	1.123	
3	8-Jan-22	0:00:00	8-Jan-22	24:00:00	24:00:00	47.00	1.128	
4	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0.00	0.000	
5	8-Jan-22	0:00:00	8-Jan-22	24:00:00	24:00:00	48.00	1.128	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	Today (i.e. 09.01.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. SSP RBPH Unit No. 2 is under AOH from 24.12.2021.
2	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	
3	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	
4	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	
5	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	
6	8-Jan-22	0:00:00	8-Jan-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.379	0.000	3.379
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	27.586	0.000	27.586
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Jan-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 126.13 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6163 Cusec 15.08 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16138 Cusec 39.48 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15116	620

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
625	0	16977	16138	0	337	27.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 5: 00:10 hrs on 09.01.2022 to 06:05 hrs on 09.01.2022.

Unit No. 6: 00:20 hrs on 09.01.2022 to 06:10 hrs on 09.01.2022.

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Handwritten signature and date:
09/01/22
J.E. (EMC)
EMC, NCA, I.D.