



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Jan-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 09-Jan-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 9-Jan-22 | 2:17:00 | 9-Jan-22 | 22:00:00 | 19:43:00 | 47.00 | 0.910 | Today (i.e. 10.01.2022), 3 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 24:00:00 | 24:00:00 | 47.00 | 1.119 | |
| 3 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 24:00:00 | 24:00:00 | 48.00 | 1.126 | |
| 4 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 1:17:00 | 1:17:00 | 47.00 | 0.060 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|----------------------------------|----------|----------------------------------|-------------|----------------|-------------------|---|
| 1 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today (i.e. 10.01.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. SSP RBPH Unit No. 2 is under AOH from 24.12.2021. |
| 2 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 9-Jan-22 | 10:03 11:07 11:32 11:55 | 9-Jan-22 | 10:42 11:15 11:36 12:40 | 1:36:00 | 61 | 0.048 | |
| 4 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 9-Jan-22 | 0:00:00 | 9-Jan-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.215 | 0.048 | 3.263 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 30.801 | 0.048 | 30.849 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 69:00:00 | 1:36:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 72:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 48:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 10-Jan-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 126.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2622 Cusec 6.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14566 Cusec 35.64 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 16977 | 625 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|-------|-------|------|----------|----------|
| 616 | 0 | 16561 | 14472 | 94 | 336 | 27.00 |



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE
10/1/22

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 5: 20:35 hrs on 09.01.2022 to 06:30 hrs on 10.01.2022.

Unit No. 4: 20:45 hrs on 09.01.2022 to 06:25 hrs on 10.01.2022.