



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Jan-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 21-Jan-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jan-22	0:00:00	21-Jan-22	24:00:00	24:00:00	45.00	1.041	Today (i.e. 22.01.2022), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	21-Jan-22	0:00:00	21-Jan-22	24:00:00	24:00:00	44.00	1.033	
3	21-Jan-22	0:00:00	21-Jan-22	24:00:00	24:00:00	45.00	1.055	
4	21-Jan-22	00:00 19:20	21-Jan-22	11:30 19:40	11:50:00	44.00	0.507	
5	21-Jan-22	17:00:00	21-Jan-22	24:00:00	7:00:00	44.00	0.291	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	Today (i.e. 22.01.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.  SSP Unit No. 3 is under AOH from 17.01.2022.
2	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	
3	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	
4	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	
5	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	
6	21-Jan-22	0:00:00	21-Jan-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.927	0.000	3.927
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	74.538	0.048	74.586
PREVIOUS DAY ACTUAL RUNNING HOURS	90:50:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Jan-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.02 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5744 Cusec 14.05 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19503 Cusec 47.72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21492	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	20664	19503	0	310	29.00



for *Rajesh Sharma*

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

J.E.(EMC,  
N.C.A.)

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.4: 21:20 Hrs on 21.01.2022 to 06:45 Hrs on 22.01.2022.

Unit No.2: 21:30 Hrs on 21.01.2022 to 06:50 Hrs on 22.01.2022.