



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Feb-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Feb-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Feb-22	10:00:00	3-Feb-22	24:00:00	14:00:00	41.00	0.561	Today (i.e. 04.02.2022), 3SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Feb-22	0:00:00	3-Feb-22	24:00:00	24:00:00	41.00	0.963	
3	3-Feb-22	0:00:00	3-Feb-22	24:00:00	24:00:00	41.00	0.975	
4	3-Feb-22	0:00:00	3-Feb-22	24:00:00	24:00:00	42.00	0.979	
5	3-Feb-22	0:00:00	3-Feb-22	2:00:00	2:00:00	40.00	0.080	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	Today (i.e. 04.02.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. SSP Unit No. 3 is under AOH from 17.01.2022.
2	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	
3	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	
4	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	
5	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	
6	3-Feb-22	0:00:00	3-Feb-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.558	0.000	3.558
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.704	0.000	10.704
PREVIOUS DAY ACTUAL RUNNING HOURS	88:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Feb-22

DATA RECEIVED FROM FLOOD CELL

RESERVOIR LEVEL IN Metres	122.69 Mtrs.	
AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	14305 Cusec	35.00 MCM
AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	20589 Cusec	50.37 MCM
GOG WATER REQUIREMENT (Next Day) in Cusec		

HR	GODBOLE
21082	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
0	0	20664	20589	0	379	29.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

Rajesh Sharma
4/2/22