



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Mar-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Mar-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Mar-22	11:30:00	6-Mar-22	23:00:00	11:30:00	37.00	0.417	Today (i.e. 07.03.2022), 3 SSP-CHPH M/c's are running at 10:00 hrs.
2	6-Mar-22	0:00:00	6-Mar-22	24:00:00	24:00:00	38.00	0.882	
3	6-Mar-22	0:00:00	6-Mar-22	24:00:00	24:00:00	38.00	0.882	
4	6-Mar-22	0:00:00	6-Mar-22	24:00:00	24:00:00	37.00	0.881	
5	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	Today (i.e. 07.03.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. RBPH Unit no. 5 is under AOH from 03.03.2022
2	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	
3	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	
4	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	
5	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	
6	6-Mar-22	0:00:00	6-Mar-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.062	0.000	3.062
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.195	0.000	18.195
PREVIOUS DAY ACTUAL RUNNING HOURS	83:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Mar-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.37 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11938 Cusec 29.21 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18164 Cusec 44.44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19525	613

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
610	0	19576	18164	0	438	28.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil