



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Mar-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Mar-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Mar-22	00:00 14:00	19-Mar-22	00:45 24:00	10:45:00	35.00	0.372	Today (i.e. 20.03.2022), 3 SSP-CHPH M/c are running at 10:00 hrs.
2	19-Mar-22	0:00:00	19-Mar-22	24:00:00	24:00:00	35.00	0.837	
3	19-Mar-22	0:00:00	19-Mar-22	24:00:00	24:00:00	34.00	0.835	
4	19-Mar-22	0:00:00	19-Mar-22	24:00:00	24:00:00	36.00	0.850	
5	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	Today (i.e. 20.03.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. RBPH Unit no. 5 is under AOH from 03.03.2022
2	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	
3	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	
4	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	
5	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	
6	19-Mar-22	0:00:00	19-Mar-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.894	0.000	2.894
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	55.576	0.000	55.576
PREVIOUS DAY ACTUAL RUNNING HOURS	82:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Mar-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18520 Cusec 45.31 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18099 Cusec 44.28 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18253	617

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
611	0	18302	18099	0	421	28.00



जल संचय - जल संरक्षण

for  
JES  
20/03/22

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

J.E. (Elect)  
EMC, N.C.A.

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 21:25 Hrs on 19.03.2022 to 05:45 Hrs on 20.03.2022.

Unit No.3: 21:35 Hrs on 19.03.2022 to 22:15 Hrs on 19.03.2022.

Unit No.6: 22:05 Hrs on 19.03.2022 to 05:50 Hrs on 20.03.2022.