



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Mar-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 24-Mar-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Mar-22	14:30:00	24-Mar-22	24:00:00	9:30:00	34.00	0.320	Today (i.e. 24.03.2022), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	24-Mar-22	0:00:00	24-Mar-22	24:00:00	24:00:00	35.00	0.823	
3	24-Mar-22	0:00:00	24-Mar-22	24:00:00	24:00:00	35.00	0.827	
4	24-Mar-22	0:00:00	24-Mar-22	24:00:00	24:00:00	35.00	0.832	
5	24-Mar-22	0:00:00	24-Mar-22	9:30:00	9:30:00	34.00	0.319	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	Today (i.e. 24.03.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	
3	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	
4	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	
5	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	
6	24-Mar-22	0:00:00	24-Mar-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.121	0.000	3.121
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	71.188	0.000	71.188
PREVIOUS DAY ACTUAL RUNNING HOURS	91:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Mar-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.15 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17086 Cusec 41.80 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19004 Cusec 46.49 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21350	615

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	20121	19004	0	417	28.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 20:30 Hrs on 24.03.2022 to 05:50 Hrs on 25.03.2022.