



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Mar-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 26-Mar-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Mar-22	0:00 10:00	26-Mar-22	1:45 24:00	15:45:00	35.00	0.531	Today (i.e. 27.03.2022), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	26-Mar-22	0:00:00	26-Mar-22	24:00:00	24:00:00	35.00	0.820	
3	26-Mar-22	0:00:00	26-Mar-22	24:00:00	24:00:00	34.00	0.794	
4	26-Mar-22	0:00:00	26-Mar-22	24:00:00	24:00:00	36.00	0.818	
5	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	Today (i.e. 27.03.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	
3	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	
4	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	
5	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	
6	26-Mar-22	0:00:00	26-Mar-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.963	0.000	2.963
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	77.245	0.000	77.245
PREVIOUS DAY ACTUAL RUNNING HOURS	87:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Mar-22
DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 118.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14661 Cusec 35.87 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18332 Cusec 44.85 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19599	615

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	19154	18332	0	416	28.00



for Asst. Engr. Kanungo
S.E. (Elect.)
27.3.22.
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil