



नर्मदा विद्युत नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Apr-22

ISSUE TIME: 10:00 Hrs

FOR DATE: 03-Apr-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 3-Apr-22 | 8:00:00 | 3-Apr-22 | 24:00:00 | 16:00:00 | 33.00 | 0.541 | Today (i.e. 04.04.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. |
| 2 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|----------------|----------|---------------|-------------|----------------|-------------------|--|
| 1 | 3-Apr-22 | 00:00 21:45 | 3-Apr-22 | 1:45 24:00 | 4:00:00 | 164 | 0.648 | Today (i.e. 04.04.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. |
| 2 | 3-Apr-22 | 6:15:00 | 3-Apr-22 | 9:15:00 | 3:00:00 | 164 | 0.488 | |
| 3 | 3-Apr-22 | 00:00 22:00 | 3-Apr-22 | 2:00 24:00 | 4:00:00 | 163 | 0.642 | |
| 4 | 3-Apr-22 | 6:30:00 | 3-Apr-22 | 9:30:00 | 3:00:00 | 165 | 0.484 | RBPH Unit no. 6 is under AOH from 28.03.2022. |
| 5 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 3-Apr-22 | 0:00:00 | 3-Apr-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 0.541 | 2.262 | 2.803 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 1.714 | 6.740 | 8.454 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 16:00:00 | 14:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 13:30:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 13:30:00 | |

SSP hydrological data : at 08:00 Hrs on 4-Apr-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 118.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19338 Cusec 47.31 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8883 Cusec 21.73 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 3967 | 620 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|------|------|------|----------|----------|
| 610 | 0 | 5544 | 4938 | 3945 | 530 | 28.00 |



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

J.B. (Elect)
EMC, NCA

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil