



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Apr-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Apr-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------------|-----------|---------------|-------------|----------------|-------------------|---|
| 1 | 20-Apr-22 | 0:00 17:05 | 20-Apr-22 | 5:30 24:00 | 12:25:00 | 36.00 | 0.441 | Today (i.e. 21.04.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2 | 20-Apr-22 | 20:00:00 | 20-Apr-22 | 24:00:00 | 4:00:00 | 37.00 | 0.136 | |
| 3 | 20-Apr-22 | 0:00:00 | 20-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 20-Apr-22 | 0:00:00 | 20-Apr-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 20-Apr-22 | 0:00:00 | 20-Apr-22 | 17:10:00 | 17:10:00 | 37.00 | 0.614 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 20-Apr-22 | 0:00:00 | 20-Apr-22 | 2:00:00 | 2:00:00 | 169 | 0.342 | Today (i.e. 21.04.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. |
| 2 | 20-Apr-22 | 21:45:00 | 20-Apr-22 | 24:00:00 | 2:15:00 | 169 | 0.384 | |
| 3 | 20-Apr-22 | 0:00:00 | 20-Apr-22 | 2:15:00 | 2:15:00 | 169 | 0.376 | |
| 4 | 20-Apr-22 | 22:00:00 | 20-Apr-22 | 24:00:00 | 2:00:00 | 169 | 0.346 | |
| 5 | 20-Apr-22 | 5:15:00 | 20-Apr-22 | 8:30:00 | 3:15:00 | 167 | 0.546 | |
| 6 | 20-Apr-22 | 5:30:00 | 20-Apr-22 | 8:45:00 | 3:15:00 | 168 | 0.546 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 1.191 | 2.540 | 3.731 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 15.818 | 47.172 | 62.990 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 33:35:00 | 15:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 15:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 15:00:00 | |

SSP hydrological data : at 08:00 Hrs on 21-Apr-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29078 Cusec 71.14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10736 Cusec 26.27 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 6970 | 616 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|------|------|------|----------|----------|
| 620 | 0 | 7195 | 7473 | 3263 | 571 | 28.00 |



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNLI,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil